Printed Date: 05/04/2021 KID013A v2.0



CABINET FOR HEALTH AND FAMILY SERVICES OFFICE OF INSPECTOR GENERAL

Andy Beshear Governor

Melissa A. Moore, Director **Division of Regulated Child Care** Northern Branch 908 W. Broadway, 10-W Louisville, KY 40203 Phone: (502) 595-5781 Fax: (502) 595-5773 https://chfs.ky.gov/agencies/os/oig

Eric C. Friedlander Secretary

Adam Mather Inspector General

Inspection Report

Provider Information

Provider Type: LICENSED TYPE I

Capacity: 170

Director(s): Wells, Elissa Louise

Inspection No: 292250

CLR No: 1356305

Provider Address: 820 Pennsylvania Avenue, Bardstown, KY, 40004 Owner(s): Little Angels Primary House II, LLC

Inspection Information

Inspection Type: Investigation

Date Initiated: 11/13/2019 2:20 PM

Provider Name: Little Angels Primary House

Date Concluded: 11/14/2019 11:30 AM

No. of Children Present: 93

Inspection Report

Supervision

In Compliance

Staffing Requirements

In Compliance

In Compliance

Director Requirements Premises

Not In Compliance

610 - Building Temperature

Not In Compliance

922 KAR 2:120. Section 4. Premises Requirements.

(16) The temperature of the inside area of the premises shall be sixty-five (65) to eighty-two (82) degrees Fahrenheit.

General: Based on interview and review of documentation, the child care center failed to maintain the premises in accordance with regulatory requirements. The two (2) toddlers classrooms, located at the rear of the building had a temperature reading of sixty-one (61) degrees on 11/14/2019, as indicated by the wall thermostats. Interview with staff revealed the two (2) classrooms had maintained a temperature reading of fifty-nine (59) degrees to sixty-one (61) for the dates of 11/13/2019 and 11/14/2019. Therefore the classrooms were not maintained at the minimum temperature of sixty-five (65) degrees.

Signature of Provider/Representative Title

Date